

**ADDENDUM NO. 1
FOR
SWEET SPRINGS GROUNDWATER MONITORING WELLS PROJECT**

DATE: July 27, 2026

FROM: Wallace Group
612 Clarion Court
San Luis Obispo, CA 93401
Tel: (805) 544-4011

TO: Prospective Bidders

This addendum forms a part of the Contract Documents and modifies the original Procurement Documents dated June 2026, as noted herein. Each bidder shall acknowledge receipt of this Addendum by completing the acknowledgment at the end of this Addendum, and by confirming receipt of this addendum on the contract Bid Form. Failure to do so may subject Bidder to disqualification.

The following changes or clarifications have been made to the Bid Documents:

CHANGES TO PRIOR ADDENDA:

- NA.

CHANGES TO PROCUREMENT REQUIREMENTS:

- None.

CHANGES TO CONTRACTING REQUIREMENTS:

- None.

CHANGES TO SPECIFICATIONS:

- Section 33 24 13, Cleath-Harris Geologists, Groundwater Monitoring Report and Technical Specifications:
 - a. Regarding well drilling methodology, wells shall be drilled using direct mud rotary method.
 - b. Section 3.0 Permits, Laws and Standards. The District has processed and received the encroachment permit for the Project. Refer to Section 01 11 00, Summary of Work, including the copy of the executed Permit.
 - c. Section 14.0 Drill Cuttings and Drilling Fluids. Drill cuttings may be spread on the existing 7th Street Yard, located on 7th Street south of Nipomo Avenue and east of Ferrell Avenue. Notify District a minimum of 1 working day prior to planned deposition of cuttings (no mud or fluids), and spread cuttings in the presence of District staff, at a location determined by the District. No other site is available to accept drill cuttings; if Contractor does not utilize this option, dispose of cuttings off-site at a suitable location, at no additional cost to the District.

CHANGES TO DRAWINGS:

- NA.

RESPONSE TO OTHER QUESTIONS:

- No sound wall is required. See Section 01 11 00, Summary of Work, Para. 1.9.A Hours of Work. No night-time work is allowed, and work hours restricted to 7 am to 5 pm.
- The District will provide required environmental monitors as required to satisfy requirements of the mitigated negative declaration.

Please acknowledge receipt of this Addendum No. 1 by signing where indicated below.
**Please email a PDF copy of the signed and dated addendum to Steven Tanaka,
Wallace Group, at stevent@wallacegroup.us.**

Company Name

Date

END OF ADDENDUM